

FIELD INVESTIGATION REPORT



Frederick County Soil Conservation District

92 Thomas Johnson Drive, Suite 230
Frederick, MD 21702-4300
Phone (301) 695-2803 ext. 3
Fax (301) 694-0270



Date 6/6/24 Time Arr 10:10 Dep _____ Site Visit No. 27

SITE NAME Riverside Center Park / City Fill Area

Map Location Monocacy Blvd. Weather 80° / cloudy / rain later on

Site Contact No activity at this time! Title _____

INSPECTION TYPE: Routine Complaint

PROJECT STATUS: Started-active Started-inactive Not Started Complete

VIOLATION: Seq of Const SCE Silt Fence Earthen Dike Sediment Seed Mulch Tack Other

COMMENTS: (A) I was on site today and found no activity at this time. (gates open) (B) Dozer on site for site management which looked well managed at this time. (C) Super silt fence in good shape in areas it needs to be. (D) waters edge well protected and in good shape. (E) Rock outfall looked fantastic and working well. (F) Water quality was good. (G) Sediment curtain was removed? (H) site access very clean and well stoned. (I) Should have mowing crew take care of stabilized stock piles and site areas! (J) I took some site photos to add to report and they are attached.

Thanks! D.H. / SCD

PENALTY ADVISORY: STATE LAW PROVIDES FOR CIVIL AND CRIMINAL PENALTIES RANGING FROM \$1,000 to \$50,000 PER DAY FOR VIOLATIONS OF TITLES 4 & 9 OF THE MARYLAND ENVIRONMENT ARTICLE.

WARNING! VIOLATIONS - Sediment Control Sediment Pollution NPDES
Penalty action possible next inspection



NOTICE !! VIOLATIONS - Sediment Control Sediment Pollution NPDES
RECOMMENDING PENALTY ACTION

REPORT FAXED TO: gshankle@cityoffrederick.md.gov

ralbee@cityoffrederick.md.gov

INSPECTOR David B. Huffer

NOTE: See all pages for a complete report. This is page 1 of _____

David B. Huffer
District Urban Technician
Sediment & Erosion Control Inspector

92 Thomas Johnson Drive, Suite 230
Frederick, MD 21702-4300
Soil.Conservation@comcast.net

Phone: 301-695-2803
Cell: 301-514-5984
Fax: 301-694-0270

